

BEFORE THE ELEVATOR SAFETY BOARD
STATE OF ARKANSAS

IN RE: STONE COUNTY COURTHOUSE
STACEY AVEY, STONE COUNTY JUDGE
AS/EV #4216

CONSENT ORDER

This matter comes before the Arkansas Elevator Safety Board on Thursday, May 19, 2016. The petitioner, Stone County Judge Stacey Avey, seeks a variance for the above-referenced conveyance located at Stone County Courthouse, 107 West Main Street, Mountain View, Arkansas 72560. The petitioner seeks a variance from the overhead clearance requirement (60") contained in A18.1-2005 Section 3.1.2.2. The agency and petitioner agree that there is an undue hardship in this matter and that reasonable safety will be secured with the following conditions:

- a. installation of a "kill switch" to ensure the conveyance will not operate if the rider is not in a sitting position; and
- b. limit key access to certain county personnel; and
- c. addition of signage on landings to indicate low clearance; and
- d. the conveyance shall be properly inspected and permitted under the Arkansas Elevator Safety Law.

THEREFORE, the Board concludes that an undue hardship is present in this matter and that reasonable safety will be secured if this request is granted pursuant to the conditions contained above. The conveyance shall not operate until the conditions are completed.

IT IS SO ORDERED.

ELEVATOR SAFETY BOARD
STATE OF ARKANSAS

By: Leon Jones, Jr.
Leon Jones, Jr., Chairman

Date: 5/19/16

Approved: Denise Oxley 4/21/16 Stacey Avey 4-21-16
Denise Oxley 84-117 DATE The Honorable Stacey Avey DATE
General Counsel Stone County Judge
Arkansas Department of Labor 107 West Main Street Suite C
10421 West Markham Street Mountain View, AR 72560
Little Rock, AR 72205 (870) 269-3351
(501) 682-4504